
# Design of Energy Management System (EMS) control for Smart Grids: Case of NIDA Smart City

National Institute of Development Administration Independent Study | 8th Jan 2023 Nattapong Thanngam



## Objective

## "Minimize power costs

by using a forecasting and optimization model to control the energy storage for the coming week"



## **Conceptual**

## "3 cases comparison"

- No Solar cell installation (Present)
- Solar cell installation

Solar cell installation with EMS

Data: Smart meter of NIDA Smart city

- Train Period: 1 30 Sep. 2022
- Calculated saving period: 1 7 Oct. 2022



## **POWER COST INTRODUCTION**

## **On-Off Peak**

- **On Peak** = Mon Fri (9:00 22:00)
- **Off Peak** = Otherwise



## **Power Cost Calculation (TOU concept)**

• Power Cost = Energy Charge + Demand Charge


|                                   | On Peak | Off Peak |  |  |
|-----------------------------------|---------|----------|--|--|
| <ul> <li>Energy Charge</li> </ul> | 210     | 0        |  |  |
| <ul> <li>Demand Charge</li> </ul> | 4.3297  | 2.6369   |  |  |

Date\_Time

## **IDEA OF ENERY MANAGEMENT SYSTEM**

## Weekend

discharge power during on peak



Idea of new EMS

Current

# **NIDA's Building**

## "11 Building"

- Auditorium
- Bunchana
- Chup
- Malai
- Narathip
- Navamin

- Nida House
- Nidasumpan
- Ratchaphruek
- Serithai
- Siam







Siam





Nidsumpan





Malai



Navamin



Narathip



Auditorium



Ratchaphruek



Serithai

## **SOLAR CELL INSTALLATION AREA**



Image: solaredge.com



. . . . . . . . . . . . . . . . . . .


## ESTIMATE POWER GENERATED FROM SOLAR CELL

## Example input for Solar power generation

. . .

#### Source: solaredge.com


| SYSTEM OVERVIEW                                            | 2348 PV mod                              | ules 🔀 13                            | Inverters                      | 1174 Optimizers                    |  |  |  |
|------------------------------------------------------------|------------------------------------------|--------------------------------------|--------------------------------|------------------------------------|--|--|--|
| SIMULATION RESULT                                          | TS<br>Max Achieved AC Power<br>824.23 kW | Annual Energy Production<br>1.41 GWh | CO2 Emission Saved<br>551.25 t | Equivalent Trees Planted<br>25,319 |  |  |  |
| <ul> <li>Full area at top of 11 NIDA's building</li> </ul> |                                          |                                      |                                |                                    |  |  |  |
| <ul> <li>Installed solar panel = 974.42 kWp</li> </ul>     |                                          |                                      |                                |                                    |  |  |  |
| <ul> <li>Capacity (4 hr/day) = 3,898 kW</li> </ul>         |                                          |                                      |                                |                                    |  |  |  |




| PV MODULES |                          |            |              |             |         |      |  |
|------------|--------------------------|------------|--------------|-------------|---------|------|--|
| # Module   | Model                    | Peak power | Racking type | Orientation | Azimuth | Tilt |  |
| 360        | SunPower, SPR-P3-415-COM | 149.4 kWp  | /            |             | 125°    | 8°   |  |
| 124        | SunPower, SPR-P3-415-COM | 51.5 kWp   | 4            |             | 323°    | 6°   |  |
| 64         | SunPower, SPR-P3-415-COM | 26.6 kWp   | A            |             | 214°    | 15°  |  |
| 50         | SunPower, SPR-P3-415-COM | 20.8 kWp   | 4            |             | 304°    | 5°   |  |
| 64         | SunPower, SPR-P3-415-COM | 26.6 kWp   | Å            |             | 218°    | 15°  |  |
| 280        | SunPower, SPR-P3-415-COM | 116.2 kWp  | Å            |             | 214°    | 15°  |  |
| 96         | SunPower, SPR-P3-415-COM | 39.8 kWp   | 4            |             | 33°     | 5°   |  |
|            |                          |            |              |             |         |      |  |


## SIMPLE DIAGRAM WITH ASSUMPTION

#### Case 1: Existing



#### Case 2: Solar cell installation (No battery)








Nidsumpan

## Case 3: Solar cell installation + EMS (Battery = 100 kWh)


## **MODEL'S FLOWCHART - CASE 3**




## MATHEMATICAL MODEL - CASE 3 (WEEKDAY)

• •

Power Consumption (15 min)





Power Consumption (15 min)

Date\_Time

- ----- test
- Building: All
- Train: 1 Sep 2 Oct
- Test: 3 Oct 7 Oct



- Prophet algorithm
- MAPE = 0.1685


## MATHEMATICAL MODEL - WEEKEND (CASE 3)

ฟังก์ชันวัตถุประสงค์ (Objective Function) :

- Minimize C<sub>total</sub>
- C<sub>total</sub> = C<sub>demand charge j</sub> + C<sub>energy charge j</sub> R<sub>Solar to MEA</sub> <-- Total cost = Demand Charge cost + Energy charge cost Revenue
- $C_{energy \ charge \ j} = \sum_d \sum_{t=1}^{96} \left[ C_{t,i=MEA} * X^d_{t,i=MEA,j=l} \right]$
- *C<sub>demand charge</sub>* <-- Demand Charge cost
- $R_{Solar to MEA} = \sum_{d} \sum_{t=1}^{96} [R_{sale} * X_{t,i=s,j=MEA}^{d}]$  <-- Revenue= Power to MEA \* unit price

ตัวแปรตัดสินใจ (Decision Variable) :

- $X_{t,i=s,j=b}^d$  <-- Solar power to Battery
- $X_{t,i=b,j=l}^d$  <-- Battery power to Load (NIDA)
- $X_{t,i=s,j=l}^d$  <-- Solar power to Load
- *\_ C<sub>demand charge j</sub> <-- Peak cost*



<-- Energy Charge cost = Power consumption \* unit cost

(O = off peak, 1 = on peak)

## MATHEMATICAL MODEL - WEEKEND (CASE 3)

## ข้อจำกัด (Constraints) :

$$X_{t,i=s,j=MEA}^{d} = S_{t}^{d} - X_{t,i=s,j=l}^{d} - X_{t,i=s,j=b}^{d}; \forall d, \forall t \quad \text{--- Solar power to MEA = Solar gener}$$


$$X_{t,i=b,j=l}^{\prime d} = S_{t}^{d} - X_{t,i=s,j=l}^{\prime d} * P_{t}; \forall d, \forall t \quad \text{--- Actual Battery power to load = Ba}$$

$$B_{t,i=b}^{begin,d} = B_{t-1,i=b}^{end,d} + X_{t,i=s,j=b}^{d}; \forall d, \forall t \quad \text{--- Battery begin = Battery end (d-1)}$$

$$B_{t,i=b}^{end,d} = B_{t,i=b}^{begin,d} - X_{t,i=b,j=l}^{\prime d}; \forall d, \forall t \quad \text{--- Battery begin = Battery begin - Actual Battery begin - Actual Battery power to load = Ba}$$

$$K_{t,i=b}^{\prime d} = B_{t,i=b}^{begin,d} - X_{t,i=b,j=l}^{\prime d}; \forall d, \forall t \quad \text{--- Battery end = Battery begin - Actual Battery begin - A$$

 $C_{demand \ charge \ j} \leq X_{t,i=MEA,j=l}^{d} * C_{peak} * P_t$ ;  $\forall d, \forall t \leq P_{eak}$  cost from Decision variable <= Actual Peak cost ----



## Decision variable

- ration Solar power to load Solar power to Battery
- attery power to Load \* On/Off peak factor
- + Solar power to Battery
- ual Battery power to load
- ty Battery end
- ctual Battery power to load Solar power to load
- er generation

A week comparison




#### Case 1: Existing

Note: Only Navamin building

## Case 2: Solar cell installation

Note: Only Navamin building



### Case 3: Solar cell installation + optimization model

Note: All building

# DETAIL SUMMARY (7 DAYS) - IDEA CASE


| Case                    | Demand<br>(kW) | Peak Demand<br>(kW) | Energy charge<br>(THB) | Demand charge<br>(THB) | Total cost<br>(THB) |
|-------------------------|----------------|---------------------|------------------------|------------------------|---------------------|
| 1: No solar (Base line) | 505,460.72     | 2,218.78            | 1,831,844.37           | 465,944.64             | 2,297,789.01        |
| 2: Solar                | 478,174.37     | 2,218.78            | 1,727,662.08           | 441,630.84             | 2,169,292.92        |
| Improve from Case 1     | 5.40%          | 5.22%               | 5.69%                  | 5.22%                  | 5.59%               |
| 3: Solar cell + EMS     | 478,174.37     | 1,758.35            | 1,726,883.05           | 369,254.13             | 2,096,137.18        |
| Improve from Case 1     | 5.40%          | 20.75%              | 5.73%                  | 20.75%                 | 8.78%               |

Note:

- Optimization model (case 3) can reduce peak load due to energy storage management.
- Energy charge of case 3 can lower than case 2 due to energy storage management.
- Case 2 saving = 128,496.09 THB/week base on case 1 and On top saving = 73,155.74 THB/week

# Actual vs Forecast data

# APPLIED MODEL COMPARISON (7 DAYS)



## Actual data

## Forecast data

## DETAIL SUMMARY (7 DAYS)

| Case                  | Demand<br>(kW) | Peak Demand<br>(kW) | Energy charge<br>(THB) | Demand charge<br>(THB) | Total cost<br>(THB) |
|-----------------------|----------------|---------------------|------------------------|------------------------|---------------------|
| 3.1 Actual data       | 478,174.37     | 1,758.35            | 1,726,883.05           | 369,254.13             | 2,096,137.18        |
| 3.2 Forecast data     | 478,174.37     | 1,775.73            | 1,726,883.05           | 372,903.71             | 2,099,786.77        |
| Improve from case 3.1 | 0.00%          | -0.99%              | 0.00%                  | -0.99%                 | -0.17%              |

Note:

• After simulate battery movement pattern and apply to actual data, the demand charge is increased 1%



. . . . . . . . . . .

# A year comparison & feasibility study

# 4) SUMMARY ALL CASES (1Y BASIS)

| Case                      | Demand<br>(kW) | Peak<br>Demand<br>(kW) | Energy<br>charge<br>(THB) | Demand<br>charge<br>(THB) | Total cost<br>(THB) | Investment<br>(THB) | Saving<br>(THB/year) | Payback<br>Period<br>(year) |
|---------------------------|----------------|------------------------|---------------------------|---------------------------|---------------------|---------------------|----------------------|-----------------------------|
| 1: No solar (Base line)   | 26,283,957     | 2,219                  | 95,255,907                | 5,591,336                 | 100,847,243         | -                   | -                    | -                           |
| 2: Solar                  | 24,865,067     | 2,103                  | 89,838,428                | 5,299,570                 | 95,137,998          | 34,104,700          | 5,709,245            | 5.97                        |
| Improve from Case 1       | 5.40%          | 5.22%                  | 5.69%                     | 5.22%                     | 5.66%               |                     |                      |                             |
| 3.1: Solar + EMS (Actual) | 24,865,067     | 1,758                  | 89,797,919                | 4,431,050                 | 94,228,968          | 36,904,700          | 6,618,274            | 5.58                        |
| Improve from Case 1       | 5.40%          | 20.75%                 | 5.73%                     | 20.75%                    | 6.56%               |                     |                      |                             |
| 3.2: Solar + EMS (FCST)   | 24,865,067     | 1,776                  | 89,797,919                | 4,474,845                 | 94,272,763          | 36,904,700          | 6,574,479            | 5.61                        |
| Improve from Case 1       | 5.40%          | 19.97%                 | 5.73%                     | 19.97%                    | 6.52%               |                     |                      |                             |

- Solar cell investment --> 1 kWp = 35,000 THB, Battery Storage --> 1 kWh = 15,750 THB
- Main saving = Solar cell installation (5.66%) or 5,709,245 THB/year
- Additional saving from Energy Management System (Case 4) = +0.86% (on-top solar cell) or 865,235 THB/year
- Feasibility Study: Case 4 (Battery + EMS system) has better Payback Period than Case 1 and Case 2


#### Basis: 974.42 kWp, Battery = 100 kWh


Battery size comparison

## **BATTERY SIZE COMPARISON**



Solar + No Batter --> Peak load = 2,103







1,000 kWh --> Peak load = 1,535 kW

All

## **BATTERY SIZE COMPARISON**



- Larger battery = Greater savings
- Bigger battery = extremely large investment
- 100 kWh is the best for NIDA



# Summary



## SUMMARY

- Solar cell generation in NIDA area = 974.42 kWp
- The best case (base on Payback Period calculation) is "Solar cell + Battery 100 kWh + Energy Management System"
- Estimate investment cost = 36.90 MB
- Saving power cost = 6.57 MB/year
- Payback Period = 5.61 years
- Major saving = Solar cell installation
- Energy Management System can increase efficiency of solar cell system.

# **Observation/Suggestion**



# ENERGY MANAGEMENT SYSTEM (EMS)

• Integrating time series forecasting and optimization models into an Energy Management System (EMS) can optimize energy usage in solar cell systems by charging and discharging of power at the appropriate times.

 The feasibility study is preliminary and subject to change as it is based on assumptions regarding standard investment costs for solar cells and batteries, current electricity costs, and power consumption data for NIDA. Any changes in these parameters would affect the study's findings.

## **ENERGY MANAGEMENT SYSTEM (EMS)**

- Currently, Energy Management System (EMS) technology does not feature Time Series Forecasting and Optimization capabilities.
- The implementation of this technique significantly reduced peak demand.
- This technique has broad applicability.
- In certain cases, it may be necessary to re-evaluate the battery size. • In certain cases, it may be necessary to re-evaluate the forecasting model.

# WISDOM for Sustainable Development

สร้างบัญญาเพื่อการพัฒนาที่ยั่งยืน



สถาบันบัณฑิตพัฒนบริหารศาสตร์

2021 Independent Study

# Thank You

Aj. Sarawut Jansuwan

Aj. Kannapha Amaruchkul